

SPECIFIC TO ZONES 2 & 4

October 5, 2004

Office of Building Code Services
12055 Government Center Parkway
Suite 316
Fairfax, Virginia 22035-55-04

RTKL


RE: Tysons Corner Center Expansion
Permit # 04030B0860

- Baltimore*
- Chicago*
- Dallas*
- London*
- Los Angeles*
- Madrid*
- Miami*
- Shanghai*
- Tokyo*
- Washington*

This letter certifies that the floor and roof structure of the Expansion has been designed to support tenant provided hanging equipment (fan coil units, transformers, etc.) having a maximum weight of 750 lbs. from the floor or roof framing above. The total weight of MEP materials to be supported by one steel beam or joist shall be limited to half of this weight or 375 lbs. The tenant has been provide with a detail defining the criteria and requirements for local joist reinforcement where equipment is supported from a steel joist and this detail is to be shown on the tenant Contract Documents. The hanging system for this equipment is to be engineered by the tenant and documented on the tenant Contract Documents.

Sincerely,

RTKL Associates Inc.



Robert S. Knight, Jr., P.E.
Associate Vice President
Director of Structural Engineering

pc: Doug Morrow
Harold Thompson



901 South Bond Street
Baltimore, MD 21231-3305
T 410 537 6000
F 410 276 2136
www.rtkl.com